Mid 20, 94

Checker 1,937

May 19, 1983

Mr. Corky Winn, Manager Economy Transmission Service 215 N. Grant Springfield, MO

Dear Mr. Winns

On May 9, 1983 personnel from the City's Public Works Department received a citizen's complaint of an oil substance in the drainage ditch in the 700 block of West Olive. An inspection by personnel of the Water Pollution Control Section revealed that the oil substance was originating from your waste transmission oil underground storage tank.

As you were advised, this discharge is a violation of City, State, and Federal Water Pollution Control laws and a violation of City Health Ordinances.

Spill clean-up of the oil was attained by absorption with dry sawdust by the Springfield Public Works Department. By authority of City ordinance the City of Springfield is required to seek recovery of the costs for labor and materials used in the spill abatement effort. A summary of these costs follows:

Personnel Costs	ea.		\$29.04
Materials-sawdust	do		\$50.00
Equipment Truck T1-49 Truck T1-48	to es	l mile l mile	\$ 0.35 \$ 0.35
		Total Cost	\$79.74

Please make remittance payable to: The City of Springfield, MO, and forward to

Mr. Robert R. Schaefer, P.E. Superintendent of Sanitary Services Room 210, City Hall Springfield, MO 65802 Mr. Corky Winn, Manager Page 2 May 19, 1983

Thank you for your cooperation in this matter, and if we may be of any assistance or can answer any questions, please do not hesitate to contact me at 417-864-1924.

Yours truly,

Robert E. Corson

Water Pollution Control Inspector III

Surveillance & Enforcement

REC: js

co: Fred Fantauzzi, Director of Finance
Robert R. Schaefer, P.E., Superintendent of Sanitary Services
Henry Cole, P.E., Sanitary Engineer
John R. Hixon, Missouri Department of Natural Resources